

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7125-0476:128 Page 1 of 1

CATEGORY: Fire Alarm Devices for the Hearing Impaired

LISTEE: Harrington Signal Inc., 2519 4th Avenue, Moline, IL 61265
Contact: Andrew Keller (309) 762-0731

DESIGN: Model V1971, Series AA2, AB2 (40cd), Series CA2, CB1 (15cd), Series HA1, HB1 (110 cd), Series LA1, LB1 (15 cd) and Series SA1 (110 cd) strobe lights. Refer to listee's data sheet for additional product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as strobes for use with separately listed compatible control units, audible signal devices and speakers. Intended for wall mounting and indoor use only. Not suitable for ceiling mount.

NOTE: Formerly 7125-0811:122 (Transferred from Federal Signal Corp.)

10-08-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager